Location :		In the Cavern (near the detector)						Ca	bles	In the Counting house				
		On d	etector		Off de	tector		Lost in Cables (3 MARA	the LVPS 80VDC for TON PS)	L1 fro	ont end	L0 Muon	Trigger	ну
MUON	Front end boards	LV regulators	LV cables (~10m)	IM boards	ODE boards	SB boards	LVPS for IM, ODE and SB crates	lost in the o of tota (conside cal	cables : ~4% Il power ring 4mm2 bles)	L1 front end	LVPS for L1 FE	Trigger boards	PS	
Power consumption of chip [W]			(20% lost in cables considering 10 meters		_		75% efficiency		,		75% efficiency			
Number of chips per board			of 2mm2 cable and ~3A per cable)											
Power consumption of board [W]	1.2	30%	20%	15	50	5	75%		28.4	100	75%	100	75%	
Number of boards	7632	9.2	12	152	148	144	10.5		4%	8	0.8	84	8.4	
Total power consumption [kW]	9.2	2.8	2.4	2.3	7.4	0.8	3.5	1	.2	0.8	0.3	8.4	2.8	10.5
Cooled ?	no	no	no	yes	yes	yes	yes	no		yes	yes	yes	yes	yes
Inefficiency %	100%	100%	100%	5%	5%	5%	5%		100%	5%	5%	5%	5%	5%
cavern (detector) / counting house part %								90%	10%					
heat dissipated to air [kW]	9.2	2.8	2.4	0.115	0.37	0.04	0.175	1.08	0.12	0.04	0.015	0.42	0.14	0.525
heat removed by the cooling system [kW]	0	0	0	2.185	7.03	0.76	3.325	0	0	0.76	0.285	7.98	2.66	9.975
Total power dissipated to air [kW]				16.18							1.26	i		
Total power to be cooled with water [kW]				13.3							21.6	6		
			12		1	4								
Total electrical power consumption [kW]			29	9.6								22.8		

needed in the counting house needed in the cavern but supplied from the counting house

ure, to be confirmed			
ssipation to the air !	Total:	22.8 kW 29.6 kW	

Total power needs:

53 kW

What might be forgotten: Other sub-system that need power...? Pumps, motors, etc...?

To dimension what TS-EL will have to provide to the sub-detectors in terms of electrical power, a 30% safety (or spare) margin should be added (in addition to what is still missing).